

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	53 - Okanagan Similkameen
<b>School Name:</b>	Cawston
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2026-01-02
	Date of next inspection: 2026-03-17
	Date and type of most recent maintenance: Filter replacement
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail:
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade):
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: Yes
	Detail: Additional furnace, duct and filter cleaning in portables
<b>ORECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: Reduced air exchange percentage during colder months
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Deb Sansome
	Phone Number: 250-498-3481
	Email: dsansome@sd53.bc.ca